



Member of the FM Global Group

FM Approvals  
1151 Boston Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

***Model Code and description Bold Italic Arial 10 point***

**TORREXX Electric Vaporizer**

**Models: TX25, TX50, TX100, TX160, TX240, TX320 & TX480 - TX2560  
TX19AA, TX38AA, TX75AA, TX120AA, TX180AA, TX240AA  
XP / 1 / D / T3C Ta = 40°C**

Equipment Ratings:  
Use Arial 10 point

**Models: TX25, TX50, TX100, TX160, TX240 & TX320**

Model designations indicate rated vaporizing capacity in Kg/Hr. The vaporizers are available as either explosionproof for Class I, Division 1, Group D hazardous locations Temperature Class T3C.

**Models: TX480 - TX2560**

Models TX480 thru TX2560 are assembled by combining the outputs of the TX240 and TX320. The vaporizers are available as either explosionproof for Class I, Division 1, Group D hazardous locations Temperature Class T3C.

**Models: TX19AA, TX38AA, TX75AA, TX120AA, TX180AA, TX240AA**

Model designations indicate rated capacity in lbs/hr. The vaporizers are either explosion proof for Class I, Division 1, Group D Hazardous locations Temperature class T3C.

FM Approved for:

Algas-SDI  
Seattle, WA

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	2011
CSA-C22.2 No. 0.5	1982
CSA-C22.2 No. 30	1986
CSA-C22.2 No. 94	1991
EN 60079-0	2006
EN 60079-1	2004

Original Project ID: 3026276

Canadian Project ID: 3028109

Approval Granted: March 29, 2007

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
150113	March 1, 2013		

FM Approvals LLC

  
\_\_\_\_\_  
J.E. Marquedant  
Group Manager - Electrical

4 March 2013  
Date