



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmaprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

CX-20-a-b-c COMPEXX Process Heater

XP/II/1/D/T3C; Type 4

a= Voltage: T, U, V, W, D, X, Y, Z, or M

b= Enclosure: S, T, or P

c= Controls: T, P, C

Equipment Ratings:

Explosionproof for Class I, Division I, Group D with a T3C temperature class for hazardous locations, indoor and outdoors (Type 4) with an ambient temperature range of -20°C to +40°C.

FM Approved for:

Algas-SDI International LLC
Seattle WA 98101

To verify the availability of the Approved product, please refer to www.approvalguide.com



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

CSA C22.2 No. 0.4	R2009
CSA C22.2 No. 0.5	R2008
CSA C22.2 No. 30	R2007
CSA C22.2 No. 94	R2011
CSA C22.2 No. 142	R2009

Original Project ID: 3049279

Canadian Project ID: 3049279C

Approval Granted: November 15, 2013

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

J. E. Marquedant
Group Manager, Electrical

15 November 2013

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com