


NOTE:

10 FT. MIN. (\leq 2000 GAL.)

15 FT. MIN. ($2000 \leq$ 5000 GAL.)

25 FT. MIN. ($>$ 5000 GAL.)

THIRD ANGLE PROJECTION



DO NOT SCALE DRAWING

TOLERANCES

UNLESS OTHERWISE SPECIFIED

.X \pm
.XX \pm
.XXX \pm

ANGLE $\pm 0^\circ 30'$
FRACTIONS $\pm 1/4"$



151 S. Michigan St., Seattle, Washington, USA 98108
Tel: (206) 789-5410 Fax: (206) 789-5414

Part # N/A

Drawn By: RWP

Checked By: DN

Approved By:

Date: 7/31/2014

Scale: 1:12 AND NOTED

Job # ASDI STD

INTERPRET THIS DRAWING IN ACCORDANCE WITH ANSI/ASME Y14.5-2009

THIS DRAWING SHALL NOT BE REPRODUCED OR USED IN ANY MANNER DETRIMENTAL TO ITS INTERESTS. ALL RIGHTS RESERVED.
© COPYRIGHT ALGAS-SDI

Title: DF VAPORIZER INSTALLATION CSA B149.2

Size: B Dwg. # 1501-8004 Sht. No.: 1 of 1 Rev.: A