



FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

TORREXX Electric Vaporizer

**Models: TX 25, TX50, TX100, TX160, TX240 & TX320, TX 480-TX2560,
TX19AA, TX38AA, TX75AA, TX120AA, TX180AA, TX240AA**

Equipment Ratings:

Models: TX 25, TX50, TX100, TX160, TX240 & TX320.

Model designations indicate rated vaporizing capacity in Kg/hr. The vaporizers are either explosion proof for Class I, Division 1, Group D Hazardous locations or nonincendive for Class I, Division 2, Group D Hazardous locations.

Models: TX 480-TX2560

Models TX480 thru TX2560 are assembled by combining the outputs of the TX240 and TX320. The vaporizers are either explosion proof for Class I, Division 1, Group D Hazardous locations or nonincendive for Class I, Division 2, Group D Hazardous locations.

Models: TX19AA, TX38AA, TX75AA, TX120AA, TX180AA, TX240AA

Model designations indicate rated capacity in lbs/hr. The vaporizers are either explosion proof for Class I, Division 1, Group D Hazardous locations or nonincendive for Class I, Division 2, Group D Hazardous locations.

FM Approved for:

Algas-SDI
Seattle, WA



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600

2011

Original Project ID: 3026276

Approval Granted: 11/10/2006

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
150113	March 4, 2013		

FM Approvals LLC

J. E. Marquedant
Group Manager, Electrical

1 March 2013
Date